

Annexure C

Appendix-XIII

CERTIFICATE SAFE DRINKING WATER AND SANITARY CONDITION

Dated: 25/08/2026

No: - TC-14194-2500002660F

It is certified that an inspection team headed by Naveen Suri (SAMPLING ASSIS.) (Name of Officers with designation) from UTTAR PRADESH JAL NIGAM (RURAL), BAREILLY inspected DELHI PUBLIC SCHOOL, VILL-TAH, NEW KHATIMA BYPASS, PILIBHIT, UTTAR PRADESH on 24/08/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. LAB/BLY/2026-27/2660 dated 25.08.2026 Of UTTAR PRADESH JAL NIGAM (RURAL), BAREILLY (PHED Lab) certified that DELHI PUBLIC SCHOOL, VILL-TAH, NEW KHATIMA BYPASS, PILIBHIT, UTTAR PRADESH has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid from 25.08.2026 to 24.08.2027

Signature with Seal:

Name : Ruman Sageer

Designation: (AE)

Assistant Engineer
Division Office
U.P. Jal Nigam (Rural) Bareilly


Name & Address of the Office / Department- UP JAL NIGAM BAREILLY (RURAL).

To
MANAGER

DELHI PUBLIC SCHOOL, VILL-TAH,
NEW KHATIMA BYPASS, PILIBHIT, UTTAR PRADESH

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


Delhi Public School Pilibhit


Director

		Analysis Report District Level Water Analysis Laboratory U.P. Jal Nigam (RURAL) Near M.B. Inter Collage, Gandhi Nagar, Bareilly (U.P.)					
ULR No :- TC-14194-250000026601							
Customer Details							
Office Name and Address :			DELHI PUBLIC SCHOOL, VILL-TAH, NEW KHATIMA BYPASS, PILIBHIT (UP).				
Ref Letter No & Date :			Nil.		DATE - 24.08.2026		Report No.- LAB/BLY/2026-27/2660
Basic details of sample							
District	PILIBHIT	Tehseel	PILIBHIT	Analysis Start Date	24.08.2026		
Village/AREA	TAH	Block	-	Analysis Completion Date	25.08.2026		
Habitation	TAH	Location	DELHI PUBLIC SCHOOL	Report Issue Date	25.08.2026		
Water Source	Submersible	Sample Code	PS- 2660	Sample Depositor	VIJAY		
Quantity of Sample	1 ltr	Date of Sample Collection	24.08.2026	Sample Collector (Lab)	VIPIN KUMAR		
Receiving Date	24.08.2026	Sample Collector (Lab)	VIPIN KUMAR	Sample Depositor	VIJAY		
Sampling Method - IS17614(Part-1:2021)							
Environmental Condition							
Temperature		26°C		Humidity		52%	
Technical Data of Analysis							
S.No.	Analysis Parameter	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref.Method of Analysis	
				Acceptable Limit	Permissible Limit		
1	2	3	4	5	6	7	
1	Colour	(CU)	0	5	15	IS 3025 (Part 4):2021	
2	Odour	-	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2022	
3	Taste	-	Agreeable	Agreeable	Agreeable	IS:3025(Part-8):2023	
4	Turbidity	(NTU)	0.39	1.00	5.00	IS 3025 (Part 10) : 2023	
5	TDS	(mg/L)	182	500	2000	IS 3025 (Part 16) : 2023	
6	PH	-	7.46	6.5-8.5	6.5-8.5	IS 3025 (Part 11) : 2022	
7	Iron	(mg/L)	-	1.00	1.00	IS:3025(Part-53):2014	
8	Sulphate	(mg/L)	-	200	400	IS 3025 (Part 24) : 2022	
9	Alkalinity	(mg/L)	170	200	600	IS 3025 (Part 23) : 2023	
10	Hardness	(mg/L)	152	200	600	IS 3025 (Part 21) : 2019	
11	Chloride	(mg/L)	11	250	1000	IS 3025 (Part 32) : 2019	
12	Calcium	(mg/L)	29.6	75	200	IS:3025(Part-40):2024	
13	Magnesium	(mg/L)	18.95	30	100	APHA 23 Edition 3500Mg Method B	
14	Fluoride	(mg/L)	0.035	1	1.5	IS:3025 (Part-60):2023	
Note 1. This Certificate refers only to the particular sample(s) submitted for testing. 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory. 4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of tests report unless otherwise specified.							

Page no:-1/1

Email - anamika05anu@gmail.com
U.P.J.N.BAREILLY (RURAL) Contact No:- 7318253236


 Director

Authorized signatory


 अनिल कुमार
 मुख्यालय प्रबन्धक
 जल विश्लेषण प्रयोगशाला
 जल नगरी बरेली (गौरीगढ़)