

Annexure-C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. SDLWQTML/UJS/SSJ-37

Dated: 01-08-26

It is certified that an inspection team headed by Narendra Dugal (Sampling Assistant)

(Name of Officers with designation) from UJS, Haldwani, Nainital PHED

inspected the Shemford School Jaipur Beesa, Motahadu, Haldwani, NTL

(Name & Address of the school) on 01-08-26 (date of inspection), and on the basis of Water Test

Report (Attached) bearing no SDLWQTML/UJS/SSJ-37 dated 01-08-2026 of

UJS Haldwani UK (PHED Lab) certified that the

Shemford School Haldwani (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/U.T. Govt.

This certificate is valid till one year (01-08-27)

Signature with Seal: [Signature]

Name : Surendra Singh

Designation : chemist

Name & Address of the Office / Department : Haldwani

To

The Principal

Shemford School, Jaipur Beesa
Motahadu, Haldwani
(Name & Address of the Institution)

Authorised Signatory
Sub Divisional Level
Water Quality Testing & Monitoring Laboratory
UJS-Haldwani (Nainital)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

[Signature]
PRINCIPAL
SHEMFORD SCHOOL
Jaipur Beesa, Motahadu, Haldwani
Distt. Nainital, Uttarakhand

[Signature]
CHAIRMAN
SHEMFORD SCHOOL
Jaipur Beesa, Motahadu, Haldwani
Distt. Nainital, Uttarakhand




Sub Divisional Level Water Quality Testing Laboratory
UTTARAKHAND JAL SANSTHAN
HALDWANI, NAINITAL

Name of the Customer/ Organization:	Shemford School Jaipur Beesa, Motahaldu Haldwani Distt- Nainital	Sample Description	Shemford School Jaipur Beesa, Motahaldu Haldwani Distt- Nainital
Type of Water (Surface water/Ground water)	Drinking-Water	Start of analysis End of analysis	01-08-26 03-08-26
Sample Code:	SDLWQTML/UJS/SSJ-37	Sample collected By	Sampling Assistant
Sample Receiving Date and Time:	01-08-26 / 11:30 AM	Date of Issue Report	04-08-26

Water Quality Test Report
Testing Details

S.N.	Parameters	Acceptable Limit (As per BIS 10500-2012)	Permissible Limit (in the Absence of alternative source) (As per BIS 10500- 2012)	Results
1	Colour (Hazen units)	5	15	1
2	Odour (Agreeable)	Agreeable	Agreeable	Agreeable
3	pH@25*c	6.5 to 8.5	No relaxation	7.67
4	Alkalinity as CaCO ₃ (mg/l)	200	600	172
5	Turbidity (NTU)	1	5	0.66
6	Total dissolved solid (mg/l)	500	2000	419
7	Chloride (mg/l)	250	1000	66.11
8	Total hardness (mg/l)	200	600	306
9	Calcium(as ca) (mg/l)	75	200	58
10	Magnesium (mg/l)	30	100	39.13
11	Total coliform (MPN/100ML)	ABSENT	ABSENT	ABSENT
12	E.Coli (MPN/100ML)	ABSENT	ABSENT	ABSENT


CHEMIST,
(Surendra Singh)
SDLWQTML,
UJS Haldwani (Nainital)

**Sub Divisional Level
Water Quality Testing & Monitoring Laboratory
UJS- Haldwani (Nainital)**

Technical Manager
In-Charge of Laboratory
UJS Haldwani (Nainital)

**TECHNICAL MANAGER
Sub- Divisional Level
Water Quality Testing
& Monitoring Laboratory
UJS- Haldwani (Nainital)**