



**Sub Divisional Engineer,
Water Supply & Sanitation Sub Div. No. 4, Nabha Road,
Opposite Civil Lines Police Station, Patiala.**

E-mail: subdiv4dwss@yahoo.com



To Whom It May Concern

No. 420

Date. 9/3/26

It is certified that undersigned has checked the premises of school **St. Peters' Academy, Ajit Nagar Patiala**, as requested by school authorities vide ref no. **SPA/GEN/2025-26/1184 dt. 02.03.2026** and facilities (i.e. drinking water & sanitation) mentioned in request letter by the school authorities were found satisfactory as on date subject to following terms & conditions:

- 1) **This certificate is valid** for one year from date of issue.
- 2) The school authorities must ensure to get the water sample tested from NABL accredited lab once in quarter.
- 3) The school authorities must ensure to get the water tanks/ water coolers cleaned every six months and disinfect them.
- 4) The school authorities ensure all water tanks must be covered.
- 5) If at anytime during surprise check by the concerned authorities i.e. said tenure, if water sample found unsafe or sanitation facilities found unsatisfactory, this certificate stands null and void.


**PRINCIPAL,
St. Peter's Academy,
Patiala-147001 (Pb.)**


**MANAGER,
St. Peter's Academy,
Patiala - 147001 (Pb.)**


**Sub Divisional Engineer,
Water Supply & Sanitation,
Sub Division No. 4, Patiala.**