



**District Level Water Quality Testing and Monitoring
Laboratory Uttarakhand Jal Sansthan, Collectrate
Campus, Rudrapur (U.S.Nagar)**

TEST REPORT


Name and Address of Organization/ Customer	S.S.Global School, Gaushala Road, Turka Tisor, Sitarganj (U.S.Nagar), Uttarakhand		
Reference Sample Identification	04/UJS/DLWQTML/2026-27	Reporting Date	24/04/2026
ULR No.	-	Sample Location	Sample-01, Submerisble
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2026-04		
Duration of Analysis:	22/04/2026 to 23.04.2026		
Date and Time of Sample Received:	21/04/2026 & 01:35PM		

SN	Parameters	Test Method	Result	Acceptable Limit As per (IS10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1.	pH at 25°C	IS 3025 (Part 11) 2022,	7.72	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C mg/L	IS 3025 (Part 16), 2023	150	500Max	2000Max
3.	Turbidity, NTU	IS 3025 (Part 10), 2023	0.65	1Max	5Max
4.	Total Alkalinity (as CaCO ₃), mg/L	IS 3025 (Part 23), 2023	82	200Max	600Max
5.	Total Hardness (as CaCO ₃), mg/L	IS 3025 (Part 21), 2009	104	200Max	600Max
6.	Calcium as Ca, mg/l	IS 3025 (Part 40), 2019	31.2	75Max	200Max
7.	Chloride, mg/L	IS 3025 (Part 32), 2019	14.98	250Max	1000Max
8.	Magnesium as Mg, mg/l	APIA 24 th Ed -3500-Mg Method B:2023 (Calculation Method)	6.31	30Max	100Max
9.	Colour, Hazen, Max	IS 3025 (Part 4): 2021	Less than 5	5Max	15Max
10.	Odour	IS 3025 (Part 5) : 2018	Agreeable	Agreeable	Agreeable

Note:

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after 15 days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****


**Review and Authorize by
(Bhuwan Chandra)**

Authorized Signatory, Chemist

District Water Quality Testing
Monitoring Laboratory
Uttarakhand Jal Sansthan, U.S.Nagar

Page 01 to 01

TEST REPORT