

PROFORMA REGARDINGH SAFE DRINKING WATER AND

SANITARY CONDITION CERTIFICATE

No

Date: 04/07/2025

It is certified that an inspection team headed by Dr. HARISH CHANDRA PANDEY
(Name of Officers with designation) from Block Medical officer Incharge (Health Officer) P.H.C. Motahaldy (Nainital)
(Name of Department/Office) inspected the St. Lawrence Sr. Sec. School, Devalchaur Kham, Rampur Road Haldwani (Name and Address of the School) on 04/07/25 and found that the St. Lawrence Sr. Sec. School, Devalchaur Kham, Rampur Road Haldwani has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the Central/State/Union Territory Government.

The above valid for a period of ONE YEAR

Signature with seal:


**Medical Officer Incharge
PHC Motahaldy (Nainital)**

Name : Dr. HARISH CHANDRA PANDEY

Designation : M.O./IC P.H.C. Motahaldy

To

St. Lawrence Sr. Sec. School

Devalchaur Kham, Rampur Road

Haldwani, Nainital



Sub Divisional Level Water Quality Testing Laboratory
UTTARAKHAND JAL SANSTHAN
HALDWANI, NAINITAL

Name of the Customer/ Organization:	ST, Lawrence Sr.Sec. School Dewalchaur Kham Haldwani Distt:- Nainital	Sample Description	ST, Lawrence Sr.Sec. School Dewalchaur Kham Haldwani Distt:- Nainital
Type of Water (Surface water/Ground water)	Drinking-Water	Start of analysis End of analysis	25-05-2026 26-05-2026
Sample Code:	SDLWQTML/UJS/LSS-13	Sample collected By	Customer
Sample Receiving Date and Time:	25.05.2026 02:30 PM	Date of Issue Report	26-05-2026

Water Quality Test Report
Testing Details

S.N.	Parameters	Acceptable Limit (As per BIS 10500-2012)	Permissible Limit (in the Absence of alternative source) (As per BIS 10500- 2012)	Results
1	Colour (Hazen units)	5	15	1
2	Odour (Agreeable)	Agreeable	Agreeable	Agreeable
3	pH@25*c	6.5 to 8.5	No relaxation	7.55
4	Alkalinity as CaCO ₃ (mg/l)	200	600	104
5	Turbidity (NTU)	1	5	0.24
6	Total dissolved solid (mg/l)	500	2000	301
7	Chloride (mg/l)	250	1000	8.9
8	Total hardness (mg/l)	200	600	170
9	Calcium(as ca) (mg/l)	75	200	40
10	Magnesium (mg/l)	30	100	17
11	Total coliform (MPN/100ML)	ABSENT	ABSENT	ABSENT
12	E.Coli (MPN/100 ML)	ABSENT	ABSENT	ABSENT

CHEMIST,

(Surendra Singh)

SDLWQTML, UJS Haldwani (Nainital)

Chemist

Sub Divisional Level

Water Quality Testing & Monitoring Laboratory

UJS- Haldwani (Nainital)

Technical Manager

In-Charge Laboratory

UJS Haldwani (Nainital)

TECHNICAL MANAGER

Sub- Divisional Level

Water Quality Testing

Monitoring Laboratory

UJS- Haldwani (Nainital)