

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 4902 / जल परीक्षण / 171

Dated: 25/09/2026

It is certified that an inspection team headed by AMIT KUMAR (L.A.)

(Name of Officers with designation) from U.P. Jal Nigam (Gramin) Bijnor PHED

inspected the ST. MARY'S SCHOOL BHIKKAWALA AFZALGARH BIJNOR

(Name & Address of the school) on 24/09/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. BJ/ 2086 dated 25/09/2026

of District Level Water Analysis Laboratory
U.P. Jal Nigam (Gramin) Bijnor (PHED Lab) certified that the

ST. MARY'S SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till _____

सहायक अभियन्ता
खण्ड कार्यालय
उ.प्र. जल निगम (ग्रामीण)
बिजनौर

Signature with Seal: _____

Name

AKSHAYA KUMAR

Designation

A.E.

Name & Address of the Office / Department: _____

U.P. Jal Nigam (Gramin) Bijnor

Vikay
Quality Manager

District Level Water Analysis Laboratory

To UPIN Bijnor

ST. MARY'S SCHOOL
BHIKKAWALA AFZALGARH BIJNOR
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



District Level Water Analysis Laboratory

UP Jal Nigam (Gramin) Bijnor



Water Test Report

Report No:	4902 / 24-09-2026	Issue Date:	25-09-2026	Lab ID:	T-8682	
Remark:	This sample has been collected and submitted to the lab by the customer himself and All information related to the sample, such as customer details and basic details of the sample has been filled in as per customer's instructions. This report is not responsible for any location or source conditions. This Report is only intended to provide a testing report of the submitted sample and does not claim or take responsibility for any location or source.				Pages:	1/1

Customer Details

Contact Person	Customer	Address	ST. MARY'S SCHOOL, BHIKKAWALA P.O AFZALGARH, DIST BIJNOR (U.P)-246722
Office Name and Address	ST. MARY'S SCHOOL, BHIKKAWALA P.O AFZALGARH, DIST BIJNOR (U.P)-246722		Date:
Reference Letter No.	SMIC/128/2026-27		

Basic details of sample

District	Bijnor	Block/Area	NA
Gram Panchayat	NA	Village	NA
Habitation	NA	Location	ST. MARY'S SCHOOL
Water Source	SUBMERSIBLE	Sample No.	BJ/2086
Quantity of Sample	1lt	Sample Collection Date	24-09-2026
Receiving Date	24-09-2026	Sample Collector (Site)	Amit Kumar
Sample Depositor (at Lab)	Amit Kumar	Sampling Method	IS 17614 (Part 1):2021
Analysis Start Date	24-09-2026	Analysis Complete Date	25-09-2026
Temperature	27.2°C	Humidity	48%

Technical data

Ref. Method of Analysis

S.No	Analyzed parameters	Unit	observed Value	Specified Values as per BIS 10500 (2012)		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH @25 °C	-	7.12	6.5-8.5	6.5-8.5	IS 3025 P-11:2022
2	Turbidity	NTU	1.31	1	5	IS 3025 P-10:2023
3	TDS	mg/L	176.0	500	2000	IS 3025 P-16:2023
4	Fluoride as F ⁻	mg/L	N.T	1	1.5	4500-F Method C- (Electrode method)
5	Chloride as Cl ⁻	mg/L	9.0	250	1000	IS 3025 P-32:2019
6	Total Hardness	mg/L	120.0	200	600	IS 3025 P-21:2023
7	Total Alkalinity	mg/L	110.0	200	600	IS 3025 P-23:2023
8	Calcium as Ca	mg/L	35.81	75	200	IS 3025 P-40:2024
9	Magnesium as Mg	mg/L	7.77	30	100	IS 3025 P-46:2023
10	Iron as Fe	mg/L	0.02	1	No Relaxation	3500-Fe Method B (Phenanthroline Method)
11	Nitrate as NO ₃	mg/L	N.T	45	No Relaxation	4500- NO3 Method D (UV Screening Method)
12	Sulphate as SO ₄	mg/L	N.T	200	400	4500-SO4 Method E (Turbidimetric Method)
13	Color	Hazen	5.0	5	15	Color 2120 B (Visual Comparison Method)
14	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 7-8):2019
15	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5):2018

B.D.L- Below Detection limit, N.T- Not Tested

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports
5. The Bold and Underline observed value is a type of notation for outlier or out of the Acceptable and Permissible Limit.
6. After taken the report please give us short feedback by rating 1 to 5 star according our services

Review on Analysis

1. Only basis of above parameter analysis data values for given sample within safe range and under Acceptable Limit according to BIS 10500:2012.

Vikas Kumar Rajput

Authorize Signatory

(Chemist/Quality/Technical Manager)

District Level Water Analysis Laboratory Bijnor

Amir Kumar
Prepared By

*****End of Report*****