# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Dated: 22/07/26

Certificate No.: 252

It is certified that an inspection team headed by **CHC SUPERINTENDENT DR. AMAL PATEL** from **CHC LALGANJ RAEBARELI** Inspected the **ST. XAVIER INTERNATIONAL SCHOOL HARIPUR LALGANJ RAEBARELI** on 22/07/26 and on the basis of Water Test Report bearing no. **TC1449126000000017F** dated 22.07.2026 of **U.P JAL NIGAM** certified that the **ST. XAVIER INTERNATIONAL SCHOOL HARIPUR LALGANJ RAEBARELI** has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 22/07/2027

अधीक्षक
सामु0 स्वा0 केन्द्र
लालगंज–रायबरेली

Signature with Seal: .....
Name : **DR. AMAL PATEL**
Designation : **SUPERINTENDENT**
Name & Address of the Office/ Department: **C H C, LALGANJ**

**To**
**Manager**
**ST.XAVIER INTERNATIONAL SCHOOL**
**HARIPUR LALGANJ RAEBARELI**
**(Name & Address of the Institution)**

**Note: The certificate is to be issued by authorized officer / PHED Lab/ local bodies**

Manager
St. Xavier International School
Haripur Sareni Road, Lalganj-Raebareli

PRINCIPAL
St. Xavier International School
Lalganj, Raebareli

Scanned with OKEN Scanner

# Analysis Report

## District Level Water Analysis Laboratory, U.P. Jal Nigam
## Sultanpur road ( Rahi) Raebareli

TC-14491

| Report No. | Chemical Test/25507/2026-2027 | Date 22.07.2026 | S.No. 01 | Page No. | 1. | page 1/1 |
|---|---|---|---|---|---|---|
| U.I.R.No. | TC144912600000000017F | | | | | |

**Customer Details**

| | |
|---|---|
| Office Name and Address | ST. XAVIER INTERNATIONAL SCHOOL, Haripur, Sareni Road, Lalganj, Raebareli U.P.-229206 |
| Ref Letter No & Date | SXIS/July/R-01 Date 21.07.2026 |

**Basic Details Of Sample**

| | | | |
|---|---|---|---|
| District | Raebareli | Block | - |
| Gram Panchayat | - | Village | - |
| Habitation | - | Location | ST. XAVIER INTERNATIONAL SCHOOL |
| Water Source | R.O. Water | Sample No. | 25507 |
| Quality of Sample | 1000ml | Date of S.C. | 21.07.2026 |
| Receiving Date | 21.07.2026 | S. Collector | Ashish Kumar |
| Sample Depositer | Ashish Kumar | | |
| Analysis Start Date | 21.07.2026 | Analysis Completion Date | 22.07.2026 |

**Environmental Condition**

| | | | |
|---|---|---|---|
| Temperature | 25± 3°C | Relative Humidity | Upto 50± 15% |

**Technical Data of Analysis**

| S.No. | Analysed parameters | Unit of Measurement | Observed Value | Specified Values as per IS 10500:2012 | | Ref. Method of Analysis |
|---|---|---|---|---|---|---|
| | | | | Acceptable Limit | Permissible Limit in absence of alternate source | |
| 1 | 2 | 3 | 4 | 5 | 6 | 7 |
| 1 | Odour | - | Agreegable | Agreegable | Agreegable | IS 3025 (Part 5) 2018 (RA 2022) |
| 2 | Taste | - | Agreegable | Agreegable | Agreegable | IS 3025 (Part 8) 2023 |
| 3 | Colour | Hazen | 5 | 5 | 15 | APHA 24th Edition -2120 Colour Method B ( Platinum Cobalt Visual Comparison) 2023 |
| 4 | pH @ (23.5° C) | - | 7.010 | 6.5-8.5 | 6.5-8.5 | IS 3025 (Part 11) : 2012 (RA :2022) |
| 5 | Turbidity | NTU | 0.080 | 1.00 | 5.00 | IS 3025 (Part 10) : 2023 |
| 6 | TDS | mg/L | 68.000 | 500 | 2000 | IS 3025 (Part 16) : 2023 |
| 7 | Chloride | mg/L | 25.000 | 250 | 1000 | IS 3025 (Part 32) : 2014 (RA : 2025) |
| 8 | Total Alkalinity | mg/L | 20.000 | 200 | 600 | IS 3025 (Part 23) : 2023 |
| 9 | Total Hardness | mg/L | 0.000 | 200 | 600 | IS 3025 (Part 21) : 2009 (RA : 2023) |
| 10 | Sulphate | mg/L | 3.340 | 200 | 400 | APHA 24th Edition-45-SO4 Method E ( Turbidimetric Method):2023 |
| 11 | Calcium as (Ca) | mg/L | 2.000 | 75 | 200 | IS 3025 (Part40) 1991(RA 2019) EDTA Tritrimetric Method |
| 12 | Magnesium as (Mg) | mg/L | 0.000 | 30 | 100 | IS 3025 (Part46) 1994 (RA : 2023) |
| 13 | Fluoride | mg/L | 0.360 | 1 | 1.5 | Apha 24th Edition- 4500-F method C (Electrode Method) |
| 14 | Nitrate | mg/L | 0.000 | 45 | No Relaxation | APHA 24th Edition -4500-NO3 Method B ( UV Screening Method) 2024 |

Note
1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.
5. Sample Collection was submitted by the customer, It's only Tested in Laboratory.
6. The Result apply to the Sample as Received.
7. Source is not verified by the laboratory.

**Authorized Signatory**

( Umesh Kumar )

Technical Manager

District Level Water Analysis Laboratory U.P. Jal Nigam, Raebareli

Technical Manager

**** End Of Test Report****

Laboratory Contact details-Email- rahilabraebareli@gmail.com Mobile No. 6393[illegible]3

PRINCIPAL
St. Xavier International School
Lalganj, Raebareli

Manager
St. Xavier International School
Haripur Sareni Road, Lalganj-Raebareli